



Massachusetts Department of Environmental Protection
Bureau of Waste Prevention – Industrial Wastewater
BWP IW 38 & BWP IW 39
Permit for Industrial Sewer User

W210299
Transmittal Number

39731
Facility ID# (if known)

PERMIT NO. W210299

ATTACHMENT A

SPECIAL CONDITIONS

1. The South Hadley Landfill, Inc. (the “permittee”) is authorized to discharge industrial wastewater, including landfill leachate, from the South Hadley Sanitary Landfill located at 12 Industrial Drive, South Hadley, Massachusetts (the “Facility”) to the Town of South Hadley sewer system
2. This Permit expires five (5) years from the date of issuance. The permittee shall apply for a renewal of this Permit at least 90 days prior to the expiration date in accordance with 314 CMR 7.09 (3)(b).
3. This Permit is subject to obtaining approval of any other applicable federal, state or local authority that may have jurisdiction.
4. Industrial wastewater discharged from the site shall be in compliance with the EPA General Pretreatment Regulations for Existing and New Sources of Pollution (40 CFR 403) and all Categorical Pretreatment Standards that apply to the Facility, the Town of South Hadley’s Sewer Use Ordinance and Industrial Pretreatment Program (“IPP”), any industrial discharge permit issued by the Town of South Hadley and the local effluent limitations established therein. The most stringent limitations shall prevail.
5. The permittee shall monitor its discharge for sulfide, total sulfur, dissolved methane and the parameters specified at 310 CMR 19.132(1)(h)1 & 2 on a quarterly basis.
6. The permittee shall conduct all sampling and monitoring in accordance with 40 CFR 136. Test method RSKSOP-175 shall be used for dissolved methane.
7. The results of the monitoring required in Special Condition #5 shall be submitted to MassDEP Western Region Office by the 15th day of the month following any quarterly sampling event.
8. Concentrated chemicals and hazardous materials/wastes are prohibited from being discharged to the sewer.
9. No person owning, maintaining or using a sewer connection shall discharge or allow the discharge of wastewater through such connection which would result in a hazard to the public health or safety, creating a nuisance, or a violation of the provisions of 314 CMR 7.00 or 12.00.
10. MassDEP reserves the right to make appropriate revisions to this permit if the discharge results in a hazard to public health or safety, or creates a nuisance condition.